



**CERTIFICATO DI ANALISI / PRÜFBERICHT n°: 18AQ090**

pag 1/2

**Committente / Auftraggeber SEAB S.p.a. / A.G. - Bolzano / Bozen**

**campione / Probe : acqua per consumo umano**  
Wasser für den menschl. Gebrauch

**data del prelievo / Entnahmedatum : 24/05/2018 orario / Uhrzeit: 11:00**

**punto di prelievo / Entnahmeort : E74 - fontana murale via Roggia ang. Via Museo**

**inizio - fine analisi / Analysenbeginn - ende: 24/05/2018 - 08/06/2018**

**pannello analitico / Untersuchungsmodell : "Controllo di Verifica / Umfangreiche Kontrolle" (DLgs 31/2001)**

<b>parametri fisico - chimici</b> <b>physische - chemische Parameter</b>	<b>metodo</b> <b>methode</b>	<b>unità di misura</b> <b>Maßeinheit</b>	<b>risultato</b> <b>Ergebnis</b>	<b>limite</b> <b>Grenzwert</b> DLgs. 31/2001
Temperatura al prelievo / Temperatur am Entnahme		°C	12,6	-
Odore / Geruch		-	conforme / konform	conforme
Sapore / Geschmack		-	conforme / konform	conforme
Colore / Farbe		-	conforme / konform	conforme
Torbidità / Trübheit	APAT IRSA-CNR 2003 2110	FAU	<1	accettabile
Conducibilità / Leitfähigkeit	APAT IRSA-CNR 2003 2030	µScm <sup>-1</sup> @ 20°C	346	2500
pH / pH Wert	APAT IRSA-CNR 2003 2060	-	7,7	6,5-9,5
disinfettante residuo / übr. Desinfektionsmittel	APAT IRSA-CNR 2003 4080	mg/l	n.d.	0,2 (VG)
ammonio / Ammonium (NH <sub>4</sub> )	APAT IRSA-CNR 2003 4030 met. A1	mg/l	0,03	0,5
Ossidabilità / Oxydierbarkeit	Kubel	mg/l O <sub>2</sub>	<1	5,0
Durezza tot. / ges. Härte	APAT IRSA-CNR 2003 2040 met. B	°F	17	(VG) 15-50
Residuo secco / Trockenrest (180°C)	ponderale	mg/l	215	(VG max) 1500
Alluminio / Aluminium	S.M. 18th 92 3120	µg/l	60	200
Antimonio / Antimon	S.M. 18th 92 3120	µg/l	<1	5,0
Arsenico / Arsen	S.M. 18th 92 3120	µg/l	<1	10
Boro / Bor	S.M. 18th 92 3120	µg/l	140	1000
Cadmio / Cadmium	S.M. 18th 92 3120	µg/l	<1	5,0
Cromo / Chrom	S.M. 18th 92 3120	µg/l	<1	50
Ferro / Eisen ( Fe )	S.M. 18th 92 3120	µg/l	<10	200
Manganese / Mangan	S.M. 18th 92 3120	µg/l	<1	50
Mercurio / Quecksilber	S.M. 18th 92 3120	µg/l	<1	1,0
Nichel	S.M. 18th 92 3120	µg/l	<1	20
Piombo / Blei	S.M. 18th 92 3120	µg/l	<1	10
Rame / Kupfer	S.M. 18th 92 3120	µg/l	<10	1000
Selenio / Selen	S.M. 18th 92 3120	µg/l	<1	10
Sodio / Natrium	S.M. 18th 92 3120	mg/l	8,7	200
Vanadio / Vanadium	S.M. 18th 92 3120	µg/l	<1	50
Bromato / Bromat	EPA 300,1	µg/l	<1	10
Cianuri / Zyanide	APAT IRSA-CNR 2003 4070	µg/l	<10	50
Clorito / Chlorit	EPA 300,1	µg/l	<10	200
Cloruri / Chloride	APAT IRSA-CNR 2003 4090 met. A2	mg/l	14	250
Fluoruri / Fluoride	APAT IRSA-CNR 2003 4100 met. A	mg/l	<0,1	1,5
Nitrati / Nitrate (NO <sub>3</sub> )	APAT IRSA-CNR 2003 4040 met. A2	mg/l	7,1	50
Nitriti / Nitrite (NO <sub>2</sub> )	APAT IRSA-CNR 2003 4050	mg/l	<0,03	0,5
Solfati / Sulfate	APAT IRSA-CNR 2003 4140 met. B	mg/l	33	250

parametri fisico - chimici physische - chemische Parameter	metodo methode	unità di misura Maßeinheit	risultato Ergebnis	limite Grenzwert DLgs. 31/2001
Acrilammide / Acrylamyd	EPA 8270c	µg/l	<0,01	0,1
Benzene / Benzol	EPA 8260b	µg/l	<0,1	1,0
Benzo(a)pirene	EPA 8270c	µg/l	<0,01	0,01
Cloruro di vinile / Vinylchlorid	EPA 8260b	µg/l	<0,01	0,5
1, 2 dicloroetano	EPA 8260b	µg/l	<1	3,0
Epicloridrina	EPA 8260c	µg/l	<0,1	0,1
Idrocarburi policiclici aromatici <sup>(1)</sup> (sub Nota 9 DLgs. 31/01)	EPA 8270c	µg/l	<0,01	0,1
Tetracloroetilene + Tricloroetilene	EPA 8260b	µg/l	<1	10
Triarometani - totale <sup>(2)</sup> (sub Nota 10 DLgs. 31/01)	EPA 8260b	µg/l	<10	30

(1): somma di benzo(b)fluorantene, benzo(k)fluorantene, benzo(ghi)perilene, indeno(1,2,3,-cd)pirene

(2): cloroformio, bromoformio, diclorometano, bromodiclorometano

parametri microbiologici mikrobiologische Parameter	metodo methode	unità di misura Maßeinheit	risultato Ergebnis	limite Grenzwert DLgs. 31/2001
Batteri coliformi / Coliforme Bakterien @ 37°C	ISO 9308-1:2014	Ufc/100 ml	0	0
Escherichia coli	ISO 9308-1:2014	Ufc/100 ml	0	0
Enterococchi / Enterokokken	APAT IRSA-CNR 2003 7040 met. C	Ufc/100 ml	0	0
conteggio colonie / Koloniezahl @ 37°C	APAT IRSA-CNR 2003 7050	Ufc/1 ml	1	(VG: 10)
conteggio colonie / Koloniezahl @ 22°C	APAT IRSA-CNR 2003 7050	Ufc/1 ml	2	(VG: 100)

(n.d. = non determinato / nicht gemessen)

(VG = valore guida / Richtwert)

Osservazioni: valori nei limiti della norma citata

Bemerkungen: den Bestimmungen der angeführte Norm entsprechend.

Bolzano / Bozen, 14/06/2018

dr. Gabriele Ansaloni

N.127 Albo Profess. - Ordine Reg. dei Chimici Trentino A.A.



dr. Francesco Ansaloni

N.47636 Albo Profess. - Ordine Naz. dei Biologi

