



**CERTIFICATO DI ANALISI / PRÜFBERICHT n°: 17AQ147**

pag 1/2

Committente / Auftraggeber **SEAB S.p.a. / A.G. - Bolzano / Bozen**

campione / Probe : acqua per consumo umano  
Wasser für den menschl. Gebrauch

data del prelievo / Entnahmedatum : 08/08/2017 orario / Uhrzeit: 10:00

punto di prelievo / Entnahmeort : E01 - **Hotel Kohlernhof** - Colle / Kohlern 11, Bolzano / Bozen  
lavello cucina / Spülbecken Küche

inizio - fine analisi / Analysenbeginn -ende: 08/08/2017 - 25/08/2017

pannello analitico / Untersuchungsmodell : "Controllo di Verifica / Umfangreiche Kontrolle" (DLgs 31/2001)

parametri fisico - chimici physische - chemische Parameter	metodo methode	unità di misura Maßeinheit	risultato Ergebnis	limite Grenzwert DLgs. 31/2001
Temperatura al prelievo / Temperatur am Entnahme		°C	12,2	-
Odore / Geruch		-	conforme / konform	conforme
Sapore / Geschmack		-	conforme / konform	conforme
Colore / Farbe		-	conforme / konform	conforme
Torbidità / Trübheit	APAT IRSA-CNR 2003 2110	FAU	<1	accettabile
Conducibilità / Leitfähigkeit	APAT IRSA-CNR 2003 2030	µScm <sup>-1</sup> @ 20°C	152	2500
pH / pH Wert	APAT IRSA-CNR 2003 2060	-	7,5	6,5-9,5
disinfettante residuo / übr. Desinfektionsmittel	APAT IRSA-CNR 2003 4080	mg/l	0,03	0,2 (VG)
ammonio / Ammonium (NH <sub>4</sub> )	APAT IRSA-CNR 2003 4030 met. A1	mg/l	<0,02	0,5
Ossidabilità / Oxydierbarkeit	Kubel	mg/l O <sub>2</sub>	<1	5,0
Durezza tot. / ges. Härte	APAT IRSA-CNR 2003 2040 met. B	°F	7,5	(VG) 15-50
Residuo secco / Trockenrest (180°C)	ponderale	mg/l	110	(VG max) 1500
Alluminio / Aluminium	S.M. 18th 92 3120	µg/l	58	200
Antimonio / Antimon	S.M. 18th 92 3120	µg/l	<1	5,0
Arsenico / Arsen	S.M. 18th 92 3120	µg/l	<1	10
Boro / Bor	S.M. 18th 92 3120	µg/l	<10	1000
Cadmio / Cadmium	S.M. 18th 92 3120	µg/l	<1	5,0
Cromo / Chrom	S.M. 18th 92 3120	µg/l	<1	50
Ferro / Eisen ( Fe )	S.M. 18th 92 3120	µg/l	37	200
Manganese / Mangan	S.M. 18th 92 3120	µg/l	<1	50
Mercurio / Quecksilber	S.M. 18th 92 3120	µg/l	<1	1,0
Nichel	S.M. 18th 92 3120	µg/l	<1	20
Piombo / Blei	S.M. 18th 92 3120	µg/l	<1	10
Rame / Kupfer	S.M. 18th 92 3120	µg/l	<10	1000
Selenio / Selen	S.M. 18th 92 3120	µg/l	<1	10
Sodio / Natrium	S.M. 18th 92 3120	mg/l	4,5	200
Vanadio / Vanadium	S.M. 18th 92 3120	µg/l	<1	50
Bromato / Bromat	EPA 300,1	µg/l	<1	10
Cianuri / Zyanide	APAT IRSA-CNR 2003 4070	µg/l	<10	50
Clorito / Chlorit	EPA 300,1	µg/l	<10	200
Cloruri / Chloride	APAT IRSA-CNR 2003 4090 met. A2	mg/l	5,3	250
Fluoruri / Fluoride	APAT IRSA-CNR 2003 4100 met. A	mg/l	0,48	1,5
Nitrati / Nitrate (NO <sub>3</sub> )	APAT IRSA-CNR 2003 4040 met. A2	mg/l	13,2	50
Nitriti / Nitrite (NO <sub>2</sub> )	APAT IRSA-CNR 2003 4050	mg/l	0,1	0,5
Solfati / Sulfate	APAT IRSA-CNR 2003 4140 met. B	mg/l	4	250

parametri fisico - chimici physische - chemische Parameter	metodo methode	unità di misura Maßeinheit	risultato Ergebnis	limite Grenzwert DLgs. 31/2001
Acrilammide / Acrylamyd	EPA 8270c	µg/l	<0,01	0,1
Benzene / Benzol	EPA 8260b	µg/l	<0,1	1,0
Benzo(a)pirene	EPA 8270c	µg/l	<0,01	0,01
Cloruro di vinile / Vinylchlorid	EPA 8260b	µg/l	<0,01	0,5
1, 2 dicloroetano	EPA 8260b	µg/l	<1	3,0
Epicloridrina	EPA 8260c	µg/l	<0,1	0,1
Idrocarburi policiclici aromatici <sup>(1)</sup> (sub Nota 9 DLgs. 31/01)	EPA 8270c	µg/l	<0,01	0,1
Tetracloroetilene + Tricloroetilene	EPA 8260b	µg/l	<1	10
Triometani - totale <sup>(2)</sup> (sub Nota 10 DLgs. 31/01)	EPA 8260b	µg/l	<10	30

(1): somma di benzo(b)fluorantene, benzo(k)fluorantene, benzo(ghi)perilene, indeno(1,2,3,-cd)pirene

(2): cloroformio, bromoformio, diclorometano, bromodichlorometano

parametri microbiologici mikrobiologische Parameter	metodo methode	unità di misura Maßeinheit	risultato Ergebnis	limite Grenzwert DLgs. 31/2001
Batteri coliformi / Coliforme Bakterien @ 37°C	APAT IRSA-CNR 2003 7010 met. C	Ufc/100 ml	0	0
Escherichia coli	APAT IRSA-CNR 2003 7030 met. E	Ufc/100 ml	0	0
Enterococchi / Enterokokken	APAT IRSA-CNR 2003 7040 met. C	Ufc/100 ml	0	0
conteggio colonie / Koloniezahl @ 37°C	APAT IRSA-CNR 2003 7050	Ufc/1 ml	5	(VG: 10)
conteggio colonie / Koloniezahl @ 22°C	APAT IRSA-CNR 2003 7050	Ufc/1 ml	8	(VG: 100)

(n.d. = non determinato / nicht gemessen)

(VG = valore guida / Richtwert)

**Osservazioni:** valori nei limiti della norma citata

**Bemerkungen:** den Bestimmungen der angeführte Norm entsprechend.

Bolzano / Bozen, 28/08/2017

dr. Gabriele Ansaloni

N.127 Albo Profess. - Ordine Reg. dei Chimici Trentino A.A.



dr. Francesco Ansaloni

N.47636 Albo Profess. - Ordine Naz. dei Biologi

